

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-0028:225 Page 1 of 1

CATEGORY: Power Units

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
Contact: Lawrence Flood (203) 484-1200 Fax (203) 484-7309

DESIGN: Models FCPS-24S6 and FCPS-24S8 are power limited power supply/battery chargers used for supervision and expanded power driving capability of up to four Notification Appliance Circuits (FACP Fire Circuits, Signaling Devices) or resettable/non resettable outputs. Model ZNAC-4 Class A converter. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a Power Supply/Battery Charger for use with separately listed compatible fire alarm control units.

XLF: 7315-0075:206

1-24-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JANUARY 24, 2003

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager